

FIREXO SMALL EXTINGUISHER

Model/Product Number 809-765-347-816

| Name | Firexo 0.1 gal Extinguisher |
|----------------------------------|-----------------------------|
| Model/Product number | 809-765-347-816 |
| Capacity (gallons) | 0.1 |
| Cylinder Height (inches) | 11.4 |
| Outer Diameter (inches) | 2.6 |
| Cylinder Material | Stainless Steel |
| Pressurizing Gas | Nitrogen |
| Test Pressure (BAR & psi) | 27 (BAR) & 391 (psi) |
| Working Pressure at 68°F | 9 (BAR) & 130 (psi) |
| Weight Full (lbs) | 2.43 |
| Weight Empty (lbs) | 1.8 |
| Spray Range (ft) | 3 - 10 |
| Discharge Time at 68°F (seconds) | 10 – 12 |
| Temperature Range (°F) | plus 10.4 – plus 140 |
| Warranty | 1 yr |
| Fire Class | A/B/C/D/K |
| Gas & Liquid Gas Tested | Yes |
| CE Approval | CE 0036 |



All fires, fast.





















Ordinary Fla Combustibles

Flammable Liquids & Gases

Electrical

Combustible Metals

Cooking Oils

METHOD OF USE

Discharge all contents onto the fire from approximately 10 feet. The extinguisher should be installed, inspected, maintained and recharged in accordance with NFPA 10 (where applicable) and the manufacturers recommendations. When tested and certified to European EN3-7 this Firexo fire extinguisher has achieved the following fire test ratings; 3A/13B/C/D/E/5F. Tested to 35KV and safe to use on live electrical equipment at 1,000v at a distance of 3 feet. Tested on magnesium fires. It is recommended that potential fires involving specialist metals should be subject to a fire risk assessment. Tested on gas fires. It is recommended that fires involving flammable gases are dealt with by professional fire-fighting departments. See website for further details.

Call +1 419 573 6001

© FIREXO 2020

This data specification sheet provides guidance only. It does not represent scientific or professional advice to any recipient or third party reader.

Whilst great care has been taken to compile accurate data herein, FIREXO does not accept any responsibility or legal liability for any errors or omissions.

