FIREXO SMALL 0.1G EXTINGUISHER INSTRUCTIONS FOR USE

INTRODUCTION

How to use your Firexo fire extinguisher and the relevant safety warnings. These manufacturer's instructions can be found at www.firexo.com.

It is strongly recommended that anyone who may be expected to use this extinguisher is familiar with the contents of this document.

When tested in accordance with EN3-7, this Firexo fire extinguisher has achieved fire ratings for all European classes of fire which include - 5A / 13B / C / D / E / F. This extinguisher meets the performance requirements of UL711. This Firexo fire extinguisher has been tested to 35kv and is safe to use on live electrical equipment at 1,000 volts at a distance of 3 feet in accordance with EN 3-7.

WARNINGS

- Compressed or liquefied gas under pressure
- Do not discharge unless in the event of fire
- Only suitable for the fires tested i.e. 'Class D magnesium' does not suggest that it is suitable for other metals which require a separate fire test rating
- Keep fire extinguisher away from children
- Never throw fire extinguisher into a fire as it may explode when heated
- Protect from frost – operating temperature range plus 10.4ºF – plus 120ºF (negative 12ºC – plus 49ºC)
- Never discharge this fire extinguisher towards a person
- Do not use on electrical equipment rated in excess of 1,000 volts and ensure the operator doesn't stand in runoff water to avoid electrocution
- While Firexo simplifies the practice of operating a fire extinguisher, Firexo recommends that where possible, persons who are expected to fight small fires have received training on fire fighting techniques and the relevant hazards associated with using fire extinguishers. Your attention is drawn to OSHA requirements in addition to state by state requirements

CLASSES OF FIRE

The National Fire Protection Association (NFPA), classes fires into the following categories or 'classifications' of fire.



ORDINARY COMBUSTIBLES | FLAMMABLE LIQUIDS | ELECTRICAL EQUIPMENT | COMBUSTIBLE METALS | COOKING OILS

Firexo Inc., 2435 E. Gill Road,
Port Clinton, Ohio, 43452, USA
419-573-6001, www.firexo.com

IN CASE OF FIRE;

1. Ensure the fire alarm has been raised
2. Encourage others to evacuate the area
3. Ensure the fire department have been called

Use your Firexo extinguisher in accordance with this manual.

HOW TO USE

Ensuring you are between the fire and the exit/safe place and with your back facing the exit/safe place, stand approximately 10 feet away from the fire and follow the P.A.S.S. Code;

1. **Pull out the safety pin**
2. **Aim at the base of the fire**
3. **Squeeze the handle**
4. **Sweep from side to side**

Ensure that you discharge all contents.

Hold upright, pull out safety pin | **Aim at base of fire** | **Squeeze handle and sweep side to side**

INSTALLATION, INSPECTION, MAINTENANCE AND TESTING

Firexo recommends that this fire extinguisher is visually inspected by the user to ensure the pin and security tag is in place and not broken, the gauge reading is in the safe/green area, and there are no signs of damage or corrosion to the vessel. It is recommended that this inspection should be carried out on a monthly basis at a minimum.

This Firexo extinguisher cannot be refilled or recharged and should be disposed of immediately in the following circumstances;

- After Use
- After accidential / partial use
- If visible damage is detected
- After vandalism
- 5 years after the manufacturing date

SDS – SAFETY DATA SHEETS

As required by OSHA, safety data sheets (SDS) are available for all chemicals contained in Firexo. Please see www.firexo.com to view the safety data sheets.

FIREXO LIMITED WARRANTY

Firexo warrants its fire extinguishers to be free from defects in materials and workmanship from the date of purchase for a period of 5 years. During the warranty period, any such defects will be replaced if only factory replacement parts have been used to service the extinguisher. This warranty does not cover defects resulting from the modification, alteration, misuse, exposure to corrosive environments, improper installations or incorrect maintenance. All implied warranties, including but not limited to, warranties of fitness for purpose and merchantability, are limited to the time periods stated above. In no event shall Firexo Inc. be liable for incidental or consequential damages concerning the use or misuse of this product. This warranty gives you specific legal rights and you may also have other rights which vary from state to state.

MONTHLY INSPECTION RECORD

FASTEN TO EXTINGUISHER BEFORE INSTALLATION

DO NOT REMOVE THIS LABEL

FOLLOW THE INSPECTION GUIDANCE IN FIREXO INC. MANUFACTURER'S INSTRUCTIONS

DATE	INSPECTED BY
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	
/ /	

REPLACE AFTER ANY USE

DATE INSTALLED _____

MANUFACTURING DATE _____